

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 36/2026-27

Dated: 30/04/2026

It is certified that an inspection team headed by Srinivasa.M.V(AEE), APCH WARYA.S. (A-E)

(Name of Officers with designation) from R.D.W.S.&S, Gauribidanur

inspected the IVY CREST ACADEMY

(Name & Address of the school) on 29/04/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. APR00006 dated 30/04/2026

of R.D.W.S.&S Lab (PHED Lab) certified that

the IVY CREST ACADEMY (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till Six month [29/09/26] FOR WATER TESTING.

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

SRINIVASA.M.V.

Assistant Executive Engineer

ಸಹಾಯಕ ಕಾರ್ಯಕಾಲಕ ಅಧೀಯಂಕರ

ಗೌರಿಬಿದನುರ ಸಿಬಿಡಿ ಮತ್ತು ಸ್ವಚ್ಛತಾ ಉಪ ವಿಭಾಗ

ಗೌರಿಬಿದನುರ - 561 208

To IVY CREST ACADEMY

Unit of Vidhya Nidhi Trust (Regd)

No. 231, N.H.-69, Chikkaballapur Road

(Name & Address of the Institution)

Gauribidanur - 561208

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Chetana



PRINCIPAL
IVY CREST ACADEMY

Prasad

SECRETARY
IVY CREST ACADEMY




RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Sub Divisional Water Quality Chemical Testing Laboratory, Gowribidanur
(NABL Recognised Laboratory)


TEST REPORT					
IVY CREST ACADEMY Unit of vidhya nidhi trust(Regd) No 231,NH-69,Chikkaballapur road Gauribidanur-561208				Report date: 30/04/2026	
				Report Number: APR00006	
				Reference: Sample receipt Form	
				Sample receipt date:27/04/2026	
				Sample code: GBD26APR0006	
				Date of Sample collection: 27/04/2026	
				Analysis start date:28/04/2026	
				Analysis completion-date:29/04/2026	
				Sample collection protocol: APHA Method	
Sample Particulars: Water Purifier Plant				Sample quantity: 1 Liter	
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colour less clear Liquid					
1.	pH Value @ 26.5°C	7.35@28.3°C	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance, µS/cm@26°C	95@27.3°C	—	—	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):2023
5.	Colour, Hazen Units	1	5	15	IS 3025 (Part-4) :2021
6.	Turbidity, NTU	0.1	1	5	IS 3025 (Part-10) : 1984
7.	Total Dissolved Solids@ 105°C, mg/l	46	500	2000	IS 3025 (Part-16) : 2023
8.	Alkalinity as CaCO ₃ , mg/l	12.0	200	600	IS 3025 (Part-23) : 1986
9.	Total Hardness as CaCO ₃ , mg/l	24.3	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	6.31	75	200	IS 3025 (Part-40) : 1991
11.	Magnesium as Mg, mg/l	1.92	30	100	IS 3025 (Part-46) : 1994
12.	Chloride as Cl, mg/l	10.3	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO ₄ , mg/l	2.11	200	400	IS 3025 (Part-24) : 2022
14.	Fluoride as F, mg/l	0.21	1	1.5	APHA 24 th Edition
15.	Nitrate as NO ₃ , mg/l	2.51	45	No relaxation	APHA 24 th Edition
16.	Iron as Fe, mg/l	0.009	1	No relaxation	IS 3025 (Part-53) : 2003
Remarks: The given sample conforms to the Acceptable limit of IS: 10500:2012 RA 2018 drinking water specifications for above tested parameters only .					
Analysed by:  Analyst			Verified by:  Assistant Executive Engineer		

NOTE

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSF/DR-01.

RDWSD/WQMSF/TeR/01


PRINCIPAL
IVY CREST ACADEMY


SECRETARY
IVY CREST ACADEMY